

# Air Permeability Test Certificate

Test number 060120121. BINDT registration number 0162

Report reference number 060120121

This is to certify that the following dwelling and test results were carried out fully in compliance with Approved Document L1 of the 2006/2010 Building Regulations

(Pre - BEATTIE WORKS)

## Dwelling plot/address

House/plot number/name ..... 1 .....

Road ..... CAMPBELLS CLOSE .....

Town ..... WOODSTOCK .....

City ..... OXFORD .....

Post code ..... OX20 1PF ..... Unit type ..... HOUSE .....

Test date ..... 6 / 1 / 2012 ..... Test time ..... 11.00 am/~~pm~~ .....

Design air permeability	..... <u>N/A</u> .....m <sup>3</sup> /(h.m <sup>2</sup> )	r <sub>2</sub> =..... <u>0.9994</u> .....	(>0.98)
Measured air permeability	..... <u>13.89</u> .....m <sup>3</sup> /(h.m <sup>2</sup> )	n=..... <u>0.5945</u> .....	(12n≥0.5)
Envelope area of dwelling	..... <u>258</u> .....m <sup>2</sup>		

## Accredited tester

Name: Matthew Moore Signature Matthew Moore ..... Organisation: **Air testing Ltd**

Telephone number: **07525002433 / 01223 479 357** Email: **matthew@air-testing.net**

Carried out for BEATTIE PASSIVE BUILD SYSTEM LTD

Town ..... CHEDGRAVE .....

County ..... NORFOLK .....

**AIR TESTING LTD**  
Tel: 01223 479 357  
Mob: 07525 002433  
E-mail: bookings@air-testing.net  
www.air-testing.net

Company stamp